ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Attestation of Conformity

No. N8A 100013 0029 Rev. 00

Holder of Attestation: **HD HYUNDAI ENERGY SOLUTIONS CO., LTD.**
477, Bundangsuseo-ro, Bundang-gu
Seongnam-si, Gyeonggi-Do 13553
REPUBLIC OF KOREA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**

Mono-crystalline Silicon Photovoltaic module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062664001-00

Date, 2026-07-20

(Zhulin Zhang)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Attestation of Conformity

No. N8A 100013 0029 Rev. 00

Model(s):

HiT-HxxxNI (xxx=560 to 595, in steps of 5)
HiT-HxxxGH (xxx=675 to 740, in steps of 5)
HiT-TxxxNJ (xxx=615 to 650, in steps of 5)
HiT-TxxxNI, HiT-TxxxNI-FS
(xxx=560 to 590, in steps of 5)
HiT-TxxxNF (xxx=420 to 440, in steps of 5)
HiT-TxxxGH (xxx=665 to 740, in steps of 5)
HiT-HxxxCH, HiT-HxxxCH-ZB
(xxx=600 to 650, in steps of 5)
HiT-HxxxCF-BF, HiT-HxxxCF-BF(ZB)
(xxx=490 to 530, in steps of 5)
HiT-HxxxLF-FB(ZB) (xxx=490 to 535, in steps of 5)
HiT-HxxxCE-BF, HiT-HxxxCE-BF(ZB)
(xxx=435 to 470, in steps of 5)
HiT-HxxxLE-FB(ZB) (xxx=430 to 475, in steps of 5)
HiT-TxxxCH (xxx=585 to 650, in steps of 5)
xxx stands for rated output power at STC

Parameters:

Safety Class:	Class II
Max. system voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute Co., Ltd. No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®